

CITY OF FINDLAY
MINIMUM SPECIFICATIONS
FOR
#63 – C909 PLASTIC PIPE

Product Standard: ANSI/AWWA C909

Pipe Compound: ASTM D1784 Cell Class 12454

Gasket: ASTM F477

Integral Bell Joint: ASTM D

Certifications: ANSI/NSF 61, ANSI/NSF 14* UL 1285

Nominal Laying Length: 20 feet (Laying length tolerances are in accordance with AWWA and ASTM standards)

Installation: JM Eagle™ Ultra Blue Installation Guide, AWWA C605

Manning Coefficient (n) = 0.009

Hazen-Williams Coefficient © = 150